

# Certificate of Assessment

Quote No.: NKI6847

No. 2282

"Copyright CSIRO 2016 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Infrastructure Technologies in accordance with International Standard ISO 5660-1:2002 Reaction-to-fire tests – Heat release, smoke production and mass loss rate – Part 1: Heat release rate (cone calorimeter method) and Part 2: Smoke production rate (dynamic measurement), at 50 kW/m<sup>2</sup>, on behalf of:

Tarkett Australia Pty Ltd  
16 Anella Avenue  
CASTLE HILL 2154  
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNKI 11647 (CSIRO Test Number Reference KI 10840).

## SAMPLE

**IDENTIFICATION:** Primo Premium

## DESCRIPTION OF

**SAMPLE:** The sponsor described the tested specimen as a homogeneous polyvinyl chloride (PVC) wall covering finished with a polyurethane (PU) coating.

Nominal total thickness: 2 mm  
Nominal total mass: 3.15 kg/m<sup>2</sup>  
Colour: light grey

## SAMPLE

**CLASSIFICATION:** Group Number: Group 3  
(In accordance with Verification Method C/VM2 Appendix A Paragraph A1.2 and Paragraph A1.3 of the New Zealand Building Code.)


Average specific extinction area: 377.0 m<sup>2</sup>/kg

## Notes:

1. The results of this fire test may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all fire conditions.
2. As per Section 9 (n) of AS 5637.1:2015, the determination of the group number was based on the ISO 5660 part 1&2:2002 test, and was deemed valid in the cone calorimeter for the assignment of National Construction Code (NCC) group number.

Testing Officer: Heherson Alarde Date of Test: 8 July 2013

Issued on the 24<sup>th</sup> day of February 2016 without alterations or additions.

  
Brett Roddy

Team Leader, Fire Testing and Assessments



NATA Accredited Laboratory  
Number: 165  
Corporate Site No 3625  
Accredited for compliance with ISO/IEC 17025.

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

